



Siddhartha Spectro Pvt. Ltd.

(NABL Accredited & ISO-9001:2015 Approved Laboratory)

Address: Plot No.20, New Mandoli Industrial Area, Shahdara, Delhi-110093

CIN No: U74999DL2021PTC377846 ; Website: www.siddharthaspectro.in

E-mail: siddharthaspectro@gmail.com ; Ph.No: 9560422870, 9717980908, 9873242909, 9810161092



TC-7270

SS/MSF/S. 10.1

TEST REPORT NUMBER: 231204138-06

ULR NUMBER : TC727002300011093F

CUSTOMER DETAILS

STEEL KRAFTS

G.T. ROAD, PANIPAT, Panipat, Haryana, 132103

PHONE : 0

EMAIL : --

SAMPLE DETAILS

JOB REGISTRATION NO. 2325692

DATE OF RECEIPT 04-12-2023

DATE OF ISSUE 10-12-2023

DESCRIPTION-

CABLE TRAY SAMPLE , 300x150x2mm Ladder Tray, Pre Galvanised

Test Report

Sample ID : 231204138

Performance Date: 08-12-2023

Test Method: IS 1608(Pt-1):2022 - Tensile Test

Discipline: Mechanical		Group: Mechanical Properties of Metals	
S.No.	Test Parameter	Observations	
1	Tensile Strength (UTS);MPa	381 MPa	
2	Yield Stress (YS);MPa	254 MPa	
3	Elongation; %	27.4%	

Note: *The observations pertain only to the tested sample(s), not to its replicate or batch.*

Tested by:



Authorized Signatory

Terms & Conditions:

- 1.The sample description is not verified in all cases and is given "As described by customers". Samples are not drawn by us.
- 2.Total liability of our work is limited to the invoice amount and no liability will be accepted after the sample is returned.
- 3.Sample will be disposed off after 30 days.
- 4 The result listed refers only to the tested samples and applicable parameters.

